

Article

Grid-friendly Active Demand Strategy on Air Conditioning Class Load

Jian-hong Zhu ^{*}, Juping Gu and Min Wu

Institute of Electrical Engineering, Nantong University, Nantong, 226019 JiangSu Province, China;

e-mail: gu.jp@ntu.edu.cn; 1912310002@stmail.ntu.edu.cn

^{*} Correspondence: e-mail: jh.zhu@ntu.edu.cn; Tel.: +86-13515201945 (F.L.)

Abstract: The growing number of the accessed energy-efficient frequency conversion air conditioners is likely to generate a large number of harmonics on the power grid. The following shortage in the reactive power of peak load may trigger voltage collapse. Hence, this conflicts with people's expectations for a cozy environment. Concerning the problems mentioned above, an active management scheme is put forward to balance the electricity use and the normal operation of air conditioning systems. To be specific, schemes to suppress the low voltage ride through (LVRT) and harmonic are designed firstly. Then to deaden the adverse effects caused by nonlinear group load running on the grid, and to prevent the unexpected accidents engendered from grid malfunction, the dynamic sensing information obtained by an online monitor is analyzed, which can be seen as active supervise mechanism. The combined application of active and passive filtering technology is studied as well. Thirdly, the new energy storage is accessed reliably to cope with peak-cutting or grid breaking emergencies, and the fuzzy control algorithm is researched. Finally, system feasibility is verified by functional modules co-operation simulation, and active management target is achieved under scientific and reasonable state-of-charge (SOC) management strategy

Keywords: air conditioning group load; grid friendly; active demand; storage; coordinated control

1. Introduction

As the main facility of a building, air conditioning configurations grows fast accompanied by increased buildings, which are used by more and more enterprises and groups due to that it can provide comfortable surroundings, such as air temperature, relative humidity, cleanliness. However, the maximum load capacity designed on the central air conditioning is according to the local maximum temperature of working environment by national standard, but it works mostly at 70% of the full load, there are massive redundancy in the system designing [1]. This means that the demand for building energy consumption is improved continuously.

Consequently, massive harmonics are appeared with increased inverter air conditioners (IRC) connected to the grid [2]. The high-order harmonics may cause false triggers on other load equipment, affecting the normal operation and even run out of control [3]. On the other hand, frequency conversion may increase the power loss of transmission lines, dwindle transformer power capacitors, lead to overheating of the equipment, cut down equipment utilization life and economic benefits [4]. Techniques such as power factor correction rectifier are also used, but do not consider total harmonic processing on grid [5]. The detection and processing technology of grid harmonics must be paid attention and studied [6]. Relevant harmonic suppression technology is proposed and improved continuously [7].

In the case that the contradiction is very prominent between power supply and demand, measures as that how to use electricity safely and improve the central air conditioning cooling or chilling water system would be imperative for the host to operate efficiently and reduce energy consumption. Some experts and scholars have proposed innovative operation measures for energy-saving technologies [8]. The literature[9] proposed temporary cut out measures of air condition load when receiving an emergency request from the smart grid, or to circumvent the impact of the grid by shutting down the number of cooling group through a power demand optimization scheme, which did not sacrifice too much comfort.

With the development and utilization of new energy, coordinated scheduling of related equipment, the power mismatch between supply and demand of air conditioning load is solved to the utmost extent [10], where new energy is used to achieve the goal, but the impact of air conditioning on the grid is not considered. Of course, in order to achieve better goals of energy saving and comfort, and minimize the impact of nonlinear load operation on grid quality, LVRT and harmonic control technology are essential. Some experts have proposed some related techniques based on cost function, active consumption behavior is stimulated to deal with peak load shifts and reduce the unstable operation of the grid [11]. From the perspective of operating characteristics of air conditioning group load, designing a grid-friendly system composed of harmonic suppression and LVRT mechanism at the load side is necessary[12]. In addition, the lack of reactive power at peak load can cause voltage fall and even lead to entire system collapse, which undoubtedly has a great impact on the normal daily life of the people. Therefore, reactive power compensation technology also plays a pivotal role in the safe and stable operation of the power grid [13].

Hence, the goal of active demand-side management is proposed to cater to the energy crisis and alleviate power supply demand, mainly by changing the way of electricity consumption and improving the benefit of terminal electricity, making full use of the functions and operation characteristics of the energy storage system. On the one hand, measures are taken to reduce the electricity demand during the peak load period of the grid, as well increase the power demand during the valley period, so as to decrease the demand for grid reserve capacity. On the other hand, active demand-side management is carried out actively to suppress harmonics of the grid, protect electrical equipment during grid malfunction or LVRT, and ensure the normal operation of the load at the same time. By designing reactive power compensation and providing that on grid restoration, grid operation is prevented from collapse and system power loss, and maximize social benefits. In the following, the research works will be developed around active harmonic suppression, LVRT and reactive power compensation. The relevant schemes are designed, and the feasibility is verified by simulation.

2. Active Demand Strategy Design

Based on experience, among those meteorological factors that affect the comfort level of the human body, temperature is at the first place, the next is humidity, followed by which are wind direction and wind speed [14]. To make air conditioned meet the requirements of human comfort, the water system, wind system, cold and heat source must be coordinated and properly controlled. Generally, the following objectives such as air quality (freshness), comfort (temperature, humidity, ventilate), energy saving (minimum power consumption) must be taken into account in air conditioning control. So multi-objective working model should be expressed as Formula 1.

$$\left\{ \begin{array}{l} ssd = (1.818t + 18.18)(0.88 + 0.002f) + (t - 32)/(45 - t) - 3.2\sqrt{v} + 18.2 \\ \text{OPT(RAF)} \\ \text{Min}(\sum W_i) \end{array} \right. \quad (1)$$

Among them, ssd is the human body comfort index [15], the formula definition of comfort level is not the same according to different classification. t is the average temperature, f is the relative humidity, and v is the wind speed. The comfort formula is an empirical formula based on long term statistics of the project. $\sum W_i$ is the sum of energy consumed motor drag systems, W_i is the energy consumed by the pump and the fan. RAF is shrink of relative air freshness, the best comfort index is 59-70 and the human body feels the most comfortable and acceptable. In the selecting process of many parameters, the average temperature t and relative humidity f can be freely selected according to the actual situation, and the wind speed v is determined according to the control demand. From the perspective of meteorology, the human body feels more comfortable when the temperature is between 18 and 20 degrees and the relative humidity is between 50% and 60%. At present, the human body comfort index adopted in Jiangsu Province has 9 grades from -4 to 4, of which level 0 is the most comfortable and most acceptable [16]. It can also be seen from the formula that the air conditioning

operation is mainly the coordination work of the fans, pumps, compressors and heaters. Therefore, in the same external environment, the higher the human comfort control index, the higher the energy consumption of air conditioning equipment, the air conditioning group load simulation with typical nonlinear characteristics motors group is as shown in Figure 1.

The left side of the Figure show the power quality monitor of the current harmonics and voltage distortion caused by group load operation of the air conditioning system. The middle is the inverter system that supplies on power to air conditioning system. The right part represents the load of the air conditioning group. It includes a variable water volume system, a variable air volume system and a cold-heat source system. They are respectively composed of different motor machines, yet sensors and data analysis unit in the Figure are designed to realize active energy monitoring. Based on the analysis of load operation characteristics, friendly scheduling design on energy-saving operation is carried out. The hardware functional modules included in the overall active demand strategy are made of harmonic suppression and governance, LVRT control and reactive power compensation, peak shaving and emergency control.




Figure 1. The module structure of active demand management.

The Z-type filter and harmonic prevention circuit are designed on the DC bus side between power supply and load. It buffers current shock whenever nonlinear load group start or sudden changes from the power grid. Grid monitor is designed so that hardware chain action can work at the same time of the severe emergency grid faults such as LVRT. The energy storage and grid power supply are switched each other by interlock linkage circuit. In addition, combined with load forecasting, battery energy storage and load peak-to-peak management, a bidirectional charge-discharge circuit is designed between the DC bus and the energy storage battery. The energy is made full use during the LVRT period, the stored energy is released during peak hours to achieve partial peak load shift, ensure the normal operation of air conditioning. Once energy of battery is insufficient to maintain the load in normal operation at the peak load period, and indoor temperature and humidity are within a certain range of the human body fitness, suspension strategy is done due to delay characteristics of the central air conditioning system. The active management technology of the group load is provided by the means of flexible huff-puff characteristics of energy storage system. On the one hand, the normal power supply under the grid fault condition is guaranteed, on the other hand, the shifting peak and valley function is realized through energy scheduling technology. Of course, key technologies such as energy storage management and converter control technology must be given as far as possible. In the following, the topic will be discussed around the active demand side management technology from the aspects of harmonic processing, LVRT, and reactive power compensation.

3. Harmonic Suppression Technology

3.1. Air conditioning group load operation characteristics

The air-conditioning group is non-linear, so the rectifier circuit composed of power electronic devices and the multi-motor combination are selected in the system to simulate the operation model. During the peak period of air conditioning working, multiple air conditioners start running at the same time. The load characteristics are as shown in the top waveform in Figure 2(b), load operation would bring harmonics to the grid, the current distortion rate generated is very large, up to 14.12%. According to the standards proposed in IEEE Std 929- 2000 and IEEE Std. P1547, the control parameters of each odd harmonic and Total Harmonic Distortion (THD) rate in the power system are shown in Table 1. The non-sinusoidal current generated from the air conditioning nonlinear group load is the harmonic source on the utility grid, voltage drop is generated on the circuit impedance, which is superimposed on the sine wave voltage, results waveform distortion of grid voltage, affects the power quality [17]. Therefore, it is important to monitor and improve the electrical energy characteristics of the air conditioning nonlinear load operation. As can also be seen from Table 1, due to that the 5th, 7th, and 11th harmonic current components are larger, and the 5th and 7th harmonics accounts for 10.22% and 5.34% respectively, which are less than 4%, meeting the requirements of $n < 11$, while harmonic current components of 11, 13 and 17 sum up to 19%, more than 2%, which also do not meet the requirements. The total harmonic distortion rate is far beyond the requirements. Since the system only selects several motor models to simulate the nonlinear group load, there is still large gap compared with the actual large-scale load. If the harmonics are not processed, the consequences are serious. Therefore, it is necessary to monitor the quality of the incoming grid current by THD, and it is necessary to take measures to suppress harmonics and provide high power quality. As can be seen from Figure 2, FFT harmonic analysis results are shown that after APF (active passive filter) or PF (passive filter) processing, harmonics are suppressed to a certain extent. In the following, the operation principle of PF and APF are analyzed firstly.

Table 1. Harmonic constraint standard and actual harmonic of grid

Odd order	$n < 11$	$11 \leq n \leq 17$	$17 < n < 23$	$23 < n < 35$	$n > 35$	THD
Maximum harmonic constraint from standard	4.0%	2.0%	1.5%	0.6%	0.3%	<5%
Actual harmonic d	2.2%	19%	23%	9.5%	0.6%	14.12%

3.2 Filtering technology combining active and passive filtering

Harmonic detection is the primary link to realize APF control. The accuracy and respond speed of harmonic signal detection directly affect the compensation effect. If the detected harmonic component is not accurate, the subsequent control will be meaningless. So instantaneous reactive power harmonic current detection mode and current hysteresis control mode are used [18]. Improved APF is used to filter out most of the harmonics, PF is used to filter out other small portion.

3.2.1. APF Technology

The APF is generally a DC voltage source of the inverter. The power supply here is the energy storage system. Unlike the traditional passive compensation method, the APF injects harmonics actively. The main circuit is a controlled inverter composed of power electronic devices. By collecting the load device current, the harmonic currents are extracted and used to control the switch tubes.




Figure 2. (a) Current before and after filtering; (b) FFT harmonic before and after filtering.

The reverse polarity harmonic current signals generated by the inverter are injected into the grid, together with the load current to eliminate unwanted components. The APF includes a main circuit module, a nonlinear load module, a harmonic detection module, and a compensation current control module. The non-linear load side is fixed up three-phase current-voltage measurement module, measurement results are input to the harmonic detection circuit module to obtain command current. Compensation current control module is used to compare and control the main circuit switching device, so to compensate the system harmonics.

1. Harmonic current detection

The harmonic current detection method is based on instantaneous reactive power [19], as shown in the Figure 3. Three-phase current in the grid are i_a, i_b, i_c , fundamental current are i_{af}, i_{bf}, i_{cf} , harmonic current are $i_{ac}^*, i_{bc}^*, i_{cc}^*$, power voltage is e_a . C_{pq} is a power-current variation matrix, LPF is low-pass filtering, and the three-phase grid voltage is converted by C3-2, and is filtered by LPF to obtain a harmonic signal followed by comparing with the fundamental wave.




Figure 3. $i_p - i_q$ based harmonic detection method schematic.

2. Current hysteresis tracking control

The traditional hysteresis control principle utilizes the difference between the compensation current and the command current through the loop width, that is, constructs a hysteresis loop, 0 as the center, H and $-H$ as the upper and lower limits to ensure the difference within the hysteresis range. Then the switching action of the converter is achieved. The improved technique uses a voltage-space vector double hysteresis current tracking control method to reduce both switching frequency and current tracking error at a same time [20]. Higher harmonic components can be reduced while ensure the current response speed. The voltage SVPWM (Space Vector Pulse Width Modulation) synthesizes the reference voltage vector accurately, which improves the DC voltage utilization rate while maintaining a constant switching frequency. The idea of double hysteresis current control based on space voltage vector is as Formula 2.

$$U_k = RI_C + L \frac{dI_C}{dt} + e \quad (2)$$

Among them, U_k is the inverter output voltage vector, I_C is the corresponding output current vector, e is terminal voltage. Error current vector ΔI is defined as the difference between current reference vector I_C^* and actual output current vector I_C , as Formula 3.

$$\Delta I = I_C^* - I_C \quad (3)$$

Substituting Formula 3 into Formula 2, ignores effect of equivalent resistance, as Formula 4.

$$L \frac{d\Delta I}{dt} = \left(L \frac{dI_C^*}{dt} + e \right) - U_k \quad (4)$$

Define reference voltage vector U^* , as Formula 5.

$$U^* = L \frac{dI_C^*}{dt} + e \quad (5)$$

Can be simplified as Formula 6.

$$L \frac{d\Delta I}{dt} = U^* - U_k \quad (6)$$

When the current error vector is in a range other than the outer loop, the current error is large. Then, fast control is required, and only the partition of the error current vector is considered. In order to rapidly reduce the current error, the central axis of the range where the error current vector is located should be selected. At this time, regardless of the reference voltage vector U^* , $U^* - U_k$ will be a component that points to the origin of the coordinate along the central axis of the partition ΔI , and this component is the largest of all choices. The improved technique simulation diagram is as shown in Figure 4.




Figure 4. Improved hysteresis control simulation model.

Waveforms before and after APF harmonic processing are as shown in Figure 2a (middle) and Figure 2b (middle). It can be seen from the Figure that the distortion rate of the current has dropped significantly after APF, and near to 5.38%. Among them, the 5th, 7th, and 11th harmonics are

obviously reduced, and the harmonics basically be controlled. However, the THD still does not meet the standard of 5% or less, there are still large spikes and burrs in the filtering cycle, and the waveform is not very perfect.

3.2.2 PF Technology

PF is composed of components such as capacitors, inductors and resistors. System PF adopts LCL structure. The remaining frequency distribution not filtered out by APF is analyzed, RLC parameters are calculated to obtain suitable values. The cutoff frequency of the LC filter is determined firstly. It must be much smaller than the lowest harmonic frequency contained in the voltage, and at the same time much larger than the fundamental frequency [21]. The cutoff frequency is selected as following Formula 7.

$$10f_1 < f_L < f_{har(min)} \quad (7)$$

f_1 - fundamental frequency, $f_{har(min)}$ - lowest harmonic frequency. The cutoff frequency of the simulation is determined 2.25 kHz. According to the calculation, the filter capacitor is $2.82 \times 10^{-4} \text{C}$, the filter inductance is $1.776 \times 10^{-5} \text{H}$. The waveforms after APF and PF are as shown in Figure 2a (below) and harmonics analysis Figure 2b (below). It can be seen from the FFT analysis chart and Table 2, the total distortion rate has dropped to 2.11%, which is less than 4%.

Table 2: THD of odd harmonic before and after filter

Harmonic/number	5	7	11	13	15	17	19
Before filtering i_a/A	37.94	19.81	15.12	11.48	9.50	8.07	37.94
APF filtering i_a/A	3.20	2.97	3.03	3.15	3.04	2.91	3.20
Active and passive filtering i_a/A	2.58	2.21	0.68	0.41	0.38	0.35	2.58

It can be also seen that APF first eliminates a large number of harmonics, and PF eliminates a small number of specific components harmonics. In addition to designing of the low-voltage snubber circuit of the inductor-capacitor structure, an energy storage system as an emergency on grid malfunction is also designed.

4. Active Prevention Strategy on LVRT and Reactive Compensation

Based on the approximate circuit model design of the nonlinear group load of air conditioning, the power characteristics of the load under the ideal grid condition are monitored. However, under actual conditions, the power grid is often affected by external disturbances, the short-circuit fault has the greatest influences, and the voltage will fall, which will adversely affect the electrical equipment, and even cause the damage on equipment. In general, the common method is to cut off the electrical equipment from the grid to protect the local equipment. However, with the proportion of non-linear loads increasing [22], the traditional method will cause the grid voltage and frequency to fluctuate widely, resulting in the collapse of the whole grid system. Therefore, it is more suitable for the power equipment to own LVRT capability, energy storage system have the function.

4.1. Energy storage system based on isolated DC/DC converter

4.1.1. Topology of the energy storage system

In order to enable the system to have LVRT ability, the internal structure of the IRC can be skillfully utilized, and the energy storage system is added to the DC bus of the converter. The DC side and the energy storage system are joined together by a bidirectional DC converter, which is an isolated structure to achieve LVRT control, as shown in Figure 5.




Figure 5. Fuzzy adaptive PI control of energy storage

The DC side of the full-bridge can withstand the change of high power, and the energy storage system of the super-capacitor is connected to the push-pull side. The equivalent model of the super capacitor uses a series connection of capacitor SC and internal resistance R to function as a bidirectional flow of energy. During the process of frequent charge and discharge of the energy storage system, transient fluctuations are easily induced by the sudden change of the inductor current. Therefore, a freewheeling inductor L2 and a diode are connected in parallel on the push-pull side to make direction change of the current easy of the conduction. When the bidirectional DC converter operates in the buck mode, the current flows from the loop of L1. In the Boost mode, the current flows from the loop of L2, which can effectively solve the shortcoming of transient fluctuation of the current during the charge and discharge switching of the single inductor. In this paper, the isolated bidirectional DC/DC converter is used to realize the control of LVRT. When the DC bus voltage is greater than the rated voltage during the grid malfunction, the bidirectional DC converter works in the buck mode. At this time, the switch tubes S5 and S6 are equivalent. The diode plays the role of synchronous rectification. By controlling the conduction and deactivation of S1~S4, the excess energy on the DC side is stored to the right energy storage element. During the complementary conduction of the switching tubes S1, S4 and S2, S3, the DC-side voltage is stored in the inductor L1 through the single-phase full-bridge and the transformer, and the inductor L1 passes through the S5 and S6 during the simultaneous shutdown of S1~S4. Perform freewheeling to release energy. When the DC bus voltage is less than the rated voltage, the converter operates in the boost mode. At this time, the switch tubes S1~S4 correspond to the diodes, which play the role of synchronous rectification. The purpose of the energy storage system to transfer energy from the push-pull circuit to the DC side is achieved by controlling the switching tubes S5 and S6. During the alternate conduction of the switch tubes S5 and S6, the energy storage element transfers energy to the left DC bus through the push-pull converter and the transformer, where the inductor L2 stores energy and the current rises. During the simultaneous conduction of S5 and S6, the inductor L2 continues to flow through S5 and S6, releasing energy and decreasing the current. Therefore, the push-pull full-bridge bidirectional converter can operate in a step-up or step-down mode according to changes in the DC-side voltage during a grid malfunction, maintaining the DC bus voltage in allowable range, and achieving LVRT of the entire system.

4.1.2 Parameter design of energy storage system

1. Super capacitor capacity design

As the most important part of the energy storage system, the capacity configuration and parameter design of the super capacitor are very important. If the capacity setting is too small, the excess energy at the DC bus side during LVRT may not be absorbed, and the system requirement cannot be met. If the setting is too large, it may cause waste and increase economic costs. For a system

with a rated power of 5 kW, the power transfer efficiency of the isolated bidirectional DC converter is about 75%. Assuming the capacitance of the super capacitor C_{sc} , the initial voltage is U_{sc_init} , and the rated voltage U_{sc_final} , the charge and discharge power at the maximum instantaneous moment is expressed by Formula 8.

$$P_{sc\ max} \geq P_{r\ max} \cdot \eta = 5000W \times 0.75 = 3750W \quad (8)$$

The rated voltage on the DC side is 540V, the super capacitor voltage is set to 150V, and the LVRT time is set to 0.4s. According to Formula 9, the capacity of the super capacitor can be deduced.

$$C_{sc} \geq \frac{2\eta \cdot P_{r\ max} \cdot T_{lvert}}{U_{sc_final}^2 - U_{sc_init}^2} = \frac{2 \times 3750 \times 0.4}{540^2 - 150^2} F = 11.14mF \quad (9)$$

Consider a certain margin, set the rated capacity of the super capacitor 12mF. Firstly, in order to make the super capacitor not overcharge or over discharge in the process of LVRT, the energy storage system is protected. Secondly, considering the current withstand capability of the power electronic device in the converter, the operating voltage is set higher. It can protect these power electronics from over-current and breakdown damage.

2. Filter inductor L_{sc} design

The design value of filter inductance needs to meet the working requirements of both the Buck and Boost circuits [23]. At the early stage of LVRT, bidirectional DC/DC converter operates in Buck mode and is charged to the super capacitor by means of DC bus capacitors. In the recovery phase of LVRT, the bidirectional DC/DC converter operates in Boost mode, and the super capacitor is used. The constant current discharge mode feeds back the stored energy to the DC bus U_{dc} . Since the average current in the loop mode is lower than the maximum current in the Buck mode, the filter inductor size can be designed according to the maximum ripple current in the loop mode of the Buck mode, as following Formula (10)

$$L_{sc} = \frac{D \cdot (U_{dc}/n - U_{sc_init})}{\Delta I_{scp} \cdot f_s} \quad (10)$$

Among them, U_{dc} is the rated voltage of the DC bus. U_{sc_init} is the initial voltage of the super capacitor (150V). n is the ratio of the isolation transformer. D is the duty cycle in the Buck mode. I_{scp} is the peak value of the rated current of the super capacitor in the Buck mode. ΔI_{scp} is the maximum ripple current allowed by the circuit, usually set to 15% of the peak current rating. f_s is the switching frequency of the tube in a bidirectional DC/DC converter.

4.2 Fuzzy Adaptive Control Strategy During LVRT

Fuzzy control theory is a control strategy for studying fuzzy phenomena and belongs to nonlinear control algorithms. The main structure of fuzzy control includes fuzzification, knowledge base, fuzzy reasoning and clarity. Figure 6 shows the DC bus voltage and current waveforms of the converter before and after the energy storage configuration of the LVRT fault process.

It can be seen from the waveform that the DC bus voltage is stable after the energy storage, at 540V. During the period of 0.1s-0.4s, the analog grid voltage drops, and the battery has been in discharge until grid voltage is restored at 0.4s, so the DC bus voltage is maintained stable. The battery absorbs the energy when the DC side voltage fluctuates greatly to ensure the smooth progress during LVRT. The existence of the energy storage not only ensures LVRT ability, but also reduces the voltage fluctuation at the DC bus terminal. The voltage fluctuates at 540V, and the maximum does not exceed 541V.

4.3 Reactive Compensation During LVRT

According to power system analysis [24], the relationship curve between system voltage and reactive power can be expressed by the Formula (11), among them, U represents the system voltage.

Q represents the reactive power of the load, U_0 is the system voltage on the condition that Q is 0, and S_{sc} is the short-circuit capacity of the system.

$$U = U_0 \left(1 - \frac{Q}{S_{sc}}\right) \quad (11)$$




Figure 6. DC bus voltage during LVRT with storage.

In the case of that fluctuations of load is small, and the system voltage is much greater than the load voltage fluctuations, also the line resistance is much smaller than the impedance, the relation of reactive power and voltage are approximately linearly. When the electric load peaks or LVRT occurs, the grid voltage drops, at the same time, the reactive power is reduced, to support the reactive power required for power transmission, it is necessary to adjust the phase difference between the voltage and the current to change the power factor and provide reactive power compensation. Static Var Compensator (SVC) is a common dynamic reactive power compensation device, which adjusts output reactive power by changing its capacitive or inductive equivalent reactance, so as to achieve the purpose of controlling the corresponding bus voltage or reactive power of the system. When the system voltage is low or high, by controlling the trigger time of the switch tube, changing the trigger angle, thereby changing the size of the access admittance, to achieve the purpose of changing the amount of reactive power, so that voltage returns to the normal value. In this topic, the goal of reactive power compensation is achieved through the on-off control of the DC/AC converter at the interface between the energy storage and the grid. As shown in the Figure 7.




Figure 7 Reactive compensation during LVRT.

There is a phase deviation between the voltage and the current without reactive power compensation whether or not experienced LVRT. After reactive power compensation, the voltage and current are in the same phase, and the system operated in unit power factor, realizing aim of reactive power compensation during LVRT.

5. Active management energy coordination control algorithm and system simulation

Figure 8 is group load operation active demand management and coordination control flow chart. The management scheme developed is focus on active energy management on the demand side. Based on historical data and real-time monitoring parameters, various converters between energy storage, grid and load are reasonably controlled to realize load-friendly power supply. In the algorithm, considering the grid malfunction and the SOC of the energy storage and the peak load of the grid, the energy storage dispatch is used rationally to effectively avoid the peak power consumption.

The technical points are as follows:

- 1) Historical data of grid load operation are employed, predict grid load change. Based on weather forecast temperature and humidity, predict local air conditioning load operation data.
- 2) According to the monitored SOC data, predict the chargeable and dischargeable power of the energy storage system.
- 3) Combining grid load forecasting and local load forecasting data, using day-ahead power scheduling to achieve storage energy management.
- 4) Real-time monitoring on operating status of the air conditioner and the grid load, considering

events of the grid load peak period and grid malfunction or LVRT, the flexible entry of energy storage system supply on the air conditioning operation is set up.




Figure 8. Active demand management of group load operation coordination control flow chart.

5) Once the grid is operating normally and experiencing non-peak load period, the local air conditioning loads are supplied by the power grid. At the same time, if detected SOC is lower than 0.8, charging behavior is triggered so as to ensure that the function of energy storage system can play normally.


6) When the SOC is lower than 0.2, considering elapsed long time of the temperature and humidity change, air conditioning loads can be stopped temporarily so as to pass the load peak period. Then restart and realize staggered power supply.

7) The storage energy supplement is carried out timely during off-peak periods, so to ensure provide reactive power compensation ability to the grid in the event of LVRT or grid malfunction.

8) During the power grid supplying local air conditioning load, judged by monitoring the current distortion rate in the feeder line of the load circuit, the adaptive APF is put into use to eliminate higher proportion harmonics.

The simulation system corresponding to the coordinated control algorithm is shown in Figure 9.

Table 3 shows the main simulation parameters. In the system, dynamic monitoring of grid parameters is done, current and voltage are detected and analyzed.



Limited by the speed of serial communication, in order to solve the problem of complete display on the upper computer of the data collected by the lower computer, part of the data collected by the lower computer is firstly stored in the Excel table, and then the upper computer reads them from Excel table and display, so the abscissa displayed in the Figure is the change value of the second hand of the actual clock, which is displayed cyclically from 0 to 59 seconds. The abscissa in the left Figure can show the time of the LVRT process, but the Figure on the right does not reflect the true sinusoidal frequency. The true sinusoidal frequency is 50 Hz. The current date on the right are from Excel table, where the real sampling period from the lower computer is 10-6s, and the collected complete sine cycle contains 5000 data. However, the read data period of the host computer from Excel table is 1.75ms, and the sine waveform is continuously refreshed.




Figure 10. Waveforms of DC bus interface voltage and current in the grid side.

It also be seen from the Figure, when the grid is normally supplied local load, due to that grid voltage fluctuation, there is continuous small fluctuations in the DC bus line of AC/DC/AC. When a LVRT occurs, the air conditioning loads are directly supplied by the energy storage inverter system, which is connected to the DC bus, obviously, the voltage fluctuation of the DC bus during the LVRT process is smaller than before. Furthermore, the DC bus voltage drops no more, about 0.35v. Once the LVRT process ends after 311s, original volatility state is reproduced.

On the other hand, it can also be seen from the right current waves, no matter before or after LVRT, few harmonic components is produced. The simulation results show us as well that during the period, the maximum current amplitude increases to 6A, which is represented by the black and red lines, and then gradually recovers. So it is verified from which that the filter design can suppress actively the harmonics caused by the nonlinear load to the grid. With energy storage participating in grid fault control, DC bus voltage can be maintained constant during the grid LVRT. Once the grid is restored, the load resumes normal grid power supply. Waveforms also show that the harmonic

suppression and LVRT prevention designed can play a good role in the grid fault. Active demand management function can also be implemented.

In this manuscript, a new active demand side management strategy is proposed for the air conditioning group load operation. A collaborative control scheme is given. The research focuses on harmonic active suppression and LVRT technology, reactive compensation, and simulation software is used to design the system. The summary is as follows.

1. Research on the characteristics of the group air conditioning operation, hybrid model of the electronic circuit are determined with the similar nonlinear characteristics as the load model.
2. Research on the influence characteristics of the air conditioning load model operation on the power grid, for the harmonic characteristics, the hybrid application of the double hysteresis APF and the PF are introduced to weaken the influence of harmonics on the grid actively.
3. In view of the influence of grid LVRT on the VFC load, an active emergency prevention mechanism with dynamic energy storage switch is proposed to ensure the stable operation of the load.
4. According to the complex composition of the system, the sensor monitoring network strategy is proposed, and the upper dynamic monitoring design is implemented to realize the system coordination operation, reduce the impact of load operation on the grid.

The article totally explored an active demand energy management strategy. Compared with other active demand management strategies that focus on economic benefits, this article pays more attention to the management of power quality at the end of power consumption. Based on the analysis on complex characteristics of group load operation accessed to the grid, comprehensive consideration is given under such cases as the outburst faults and quality factors caused from the grid side and load side, where the special working characteristics of the energy storage system are full used, and the peaking-valley shifting requirement of the power grid is also taken into account. Correspondingly, designed control strategy is collaboratively focused on the filtering technology and energy storage technology, and the feasibility is verified by simulation. The results would have some application and promotion value. Of course, some work needs to be further studied in the research, for example, energy management of storage systems for dual hysteresis power supply and LVRT active prevention, depth study of energy-saving technology for VFC operation, and application of hybrid intelligent algorithm in harmonic processing. These will be studied in the future.

7. Patents

There are Chinese invention patents resulting from the work as follows:

1. 'Active demand strategy based on power-friendly air conditioning load side'. Authorization number: ZL201510243894.1. Authorization date: 10 /05/ 2017
2. 'Effective energy-saving active demand method based on power-friendly air-conditioning load side'. Authorization number: ZL201710100461.X. Authorization date: 18 /06 /2019.
3. 'Active demand method based on power-friendly air-conditioning load side to reduce system cost'. Authorization number: ZL201710239792.1. Authorization date: 29 /01 /2019.
4. 'Design method of active demand energy storage for non-linear group air-conditioning group load operation'. Application Number: 2018082401656550. Now in patent actual review stage.

Author Contributions:

The articles is finished by three authors, their individual contributions are as follows: Jian-hong Zhu, methodology formal, analysis and writing—original draft preparation; Juping Gu, investigation, project administration and funding acquisition, writing—review and editing; Min Wu, software validation. All authors have read and agreed to the published version of the manuscript.

Acknowledgments:

This work is a part of the National Natural Science Foundation of China (Grant No.61673226) and the Jiangsu Provincial Department Natural Foundation of China (Grant No.15KJB470014, Grant No.18KJA470003). Nantong Science and Technology Bureau Project of China (Grant No. JC2018116). The authors would like to thank for the supports from both the Ministry of Science and Technology and National Natural Science Foundation of China.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Shengwei, W. Intelligent buildings and building automation; Routledge, 2009.
2. Lv, Q.; Fei, Z.; Guo Z.; et al. A review of research on power system harmonic detection and its suppression methods. IEEE 4th Information Technology, Networking, Electronic and Automation Control Conference (ITNEC). **2020**; pp 1495-1500.
3. Rakhmanov, N.R.; Kurbatsky, V.G.; Guliyev, H.B.; et al. Analysis and modeling of harmonic distortions in consumer's distribution networks, containing a powerful non-linear load. E3S Web of Conf., Rudenko International Conference "Methodological Problems in Reliability Study of Large Energy Systems" (RSES). **2018**; pp 1-5.
4. Tahir, M.F.; Haoyong, C.; Idris, S.; et al. Demand response program significance, challenges and worldwide scope in maintaining power system stability. *International Journal of Advanced Computer Science and Applications (IJACSA)* **2018**, 9(6):121-131.
5. Lopez-Martin, V. M.; Azcondo, F. J.; Pigazo, A. Power quality enhancement in residential smart grids through power factor correction stages. *IEEE Transactions on industrial electronics* **2018**, 65, 8553– 8564.
6. Liu, G.; Chen, B.; Wang, K.; et al. Selective current harmonic suppression for high-speed PMSM based on high-precision harmonic detection method, *IEEE Transactions on Industrial Informatics* **2019**, 6(15), 3457-3468.
7. Moeini, A.; Zhao, H.; Wang, S. A Current-Reference-Based selective harmonic current mitigation PWM technique to improve the performance of cascaded H-Bridge multilevel active rectifiers, *IEEE Transactions on Industrial Electronics* **2018**, 1(65): 727-737.
8. Zuazua-Ros, A.; Martín-Gómez, C.; Ibañez-Puy, E.; et al. Investigation of the thermoelectric potential for heating, cooling and ventilation in buildings: characterization options and applications. *Renewable Energy* **2019**, 131, 229-239.
9. Rui, T.; Shengwei, W.; Chengchu, Y. A direct load control strategy of centralized air-conditioning systems for building fast demand response to urgent requests of smart grids. *Automation in Construction* **2018**, 87, 74–83.
10. Adriana, V.; Darío, A; Francisco, Santamaría; et al. Active demand-side management strategies focused on the residential sector. *The Electricity Journal*, **2020**, 33(3), 106734(1) - 106734(8).
11. Fengji, L.; Weicong, K.; Gianluca, R; et al. Optimal home energy management system with demand charge tariff and appliance operational dependencies. *IEEE Transactions on Smart Grid* **2020**, 11(1), 4-14
12. Jian-hong, Z.; Ju-ping, G.; Jun, D. et al. Effective energy-saving method based on active demand of electric energy-friendly air conditioning load side. China, ZL201710100461.X [P/OL]. **2019**-06-28.
13. Jia, L.; Yushi, M.; Toshifumi, I.; Cost-function-based microgrid decentralized control of unbalance and harmonics for simultaneous bus voltage compensation and current sharing. *IEEE Transactions on Power Electronics* **2019**, 34(8): 7397-7410.
14. Yan, D.; Shu, W.; Long-zhe, J.; et al. Experimental investigation and theoretical analysis of the human comfort prediction model in a confined living space. *Applied Thermal Engineering* **2018**, 141, 61–69.
15. Chengfang, Y. Analysis of REOF on body comfort in Shandong. *Journal of the Meteorological Sciences* **2006**, 01, 103 - 109.
16. Lingjiang, H.; Zhiqiang, Z. Critical review and quantitative evaluation of indoor thermal comfort indices and models incorporating solar radiation effects. *Energy & Buildings* **2020**, 224, 110204(1) - 110204(1).
17. Zhao-an, W. Harmonic suppression and reactive power compensation; Machinery Industry Press, China, 2016.
18. Xie, N.; Xu, Q; Zeng, J; et al. Novel hybrid control method for APF based on PI and FRC. *The Journal of Engineering* **2019**, 16, 3002 - 3006.
19. Moussa, H.; Martin, J.-P.; Pierfederici, S.; et al. Voltage harmonic distortion compensation with non-linear load power sharing in low-voltage islanded microgrid. *Mathematics and Computers in Simulation* **2019**, 158, 32 – 48.
20. Harshitha, H.; Dawnee, S.; Kumaran, K. Comparative study of fixed hysteresis band current controller and adaptive hysteresis band current controller for performance analysis of induction motor. 2017 International Conference on Energy, Communication, Data Analytics and Soft Computing (ICECDS). **2017**; pp 552 – 558.

21. Shiqi, J.; Yitao, L.; Weihua, L.; et al. Active EMI filter design with a modified LCL-LC filter for Single-Phase Grid-Connected inverter in Vehicle-to-Grid application. *IEEE Transactions on Vehicular Technology* **2019**, 68(11), 10639 - 10650.
22. Khalid Abdullah, K.; Muhammad, K. A reactive power compensation strategy in radial distribution network with high PV penetration. 8th International Conference on Renewable Energy Research and Applications (ICRERA). 2019; pp 434 - 438.
23. Crozier, C.; Morstyn, T.; Deakin, M.; et al. The case for Bi-directional charging of electric vehicles in low voltage distribution networks. *Applied Energy* **2020**, 259, 114214(1) - 114214(7).
24. Jun, W. Power system analysis. China Electric Power Press, 2020.